

CERTIFICATE OF ORIGIN

K-132

Exporter
M/S.KAYSON INTERNATIONAL
 B/232, OSHIWARA INDUSTRIAL CENTRE,
 OPP. GOREGAON BUS DEPOT, NEW LINK
 ROAD, GOREGAON (WEST),
 MUMBAI - 400 104. (INDIA)



399875

الغرفة الهندية العربية للتجارة والصناعة

**INDO-ARAB CHAMBER OF
COMMERCE AND INDUSTRIES**

78-B, Maker Arcade, Ground Floor,
 Cuffe Parade, Mumbai - 400 005. India.
 Tel. : 91-22-2218 3353 / 2363 / 2216 5096
 Fax : 91-22-2218 8221
 Web : www.iacci.org
 E-mail : iacci@bom3.vsnl.net.in

Consignee
BANQUE DU CAIRE
 19, ADLI STREET,
 CAIRO (EGYPT)
 A/C.
**M/S.CAIRO ORGANISATION FOR TRADING
 AND ENGINEERING,**
 1/26TH JULY STREET,
 CAIRO (EGYPT)

Pre-Carrier by AIR	Place of Receipt by Pre-Carrier
Vessel / Flight No.	Port of Loading MUMBAI AIRPORT
Port of Discharge CAIRO AIRPORT	Final Destination EGYPT

(NON PREFERENTIAL)

Marks & Nos / Container No.	No. & Kinds Of Pkgs.	Description of Goods
KAYSON		ELECTRICIAN GLOVES AS PER INVOICE INVOICE NO.KAY/EXP/131/10-11 DATED 18/01/2011.

Quantity
38 PACKAGES

- 1) WE HEREBY CERTIFY THAT THE GOODS OF THIS INVOICE ARE PRODUCED IN INDIA.
- 2) THE GOODS OF THIS INVOICE HAVE BEEN WHOLLY/PARTIALLY MANUFACTURED IN INDIA AND ALL THE EXPENDITURE INCURRED ON ALL THE MATERIAL PRODUCED AND THE LABOUR PERFORMED WITHIN INDIA IS NOT LESS THAN 50% (FIFTY PERCENT) OF THE FACTORY OR WORKS. THE COST OF THE ITEMS IN THEIR FINISHED STAGE.
- 3) THE FINAL PROCESS OF MANUFACTURE OF EACH AND EVERY ITEMS HAS BEEN PERFORMED IN INDIA.

Declaration by the exporter:
 The undersigned hereby declares that the above details and statements are correct; that all the goods were produced in India and that they comply with the origin requirements for exports to



Egypt
 (Importing country)

[Signature]
 Authorized Signatory
 (Exporting)

CERTIFICATION

It is hereby certified that to the best of our knowledge and belief the above mentioned goods are of Indian Origin.

The undersigned SECRETARY of
 INDO ARAB CHAMBER OF COMMERCE AND INDUSTRIES
 hereby certify to the best of my knowledge
 and belief that the Merchandise Specified
 thereunder is of INDIAN ORIGIN/Manufacture/
 Produce
 It is further certified the goods are
 neither of Israeli Origin Nor do they
 Contain any Israeli Materials



[Signature]
SHIVRAM DALVI
 (SR OFFICE SECRETARY)

Signature & Date

3 FEB 2011

KAYSON INTERNATIONAL

B-232, OSHIWARA INDUSTRIAL CENTRE, OPP. GOREGAON BUS DEPOT,
NEW LINK ROAD, GOREGAON (WEST), MUMBAI - 400 104.

PHONE : 878 7663, FAX :91-22-878 7664

E-mail : kapilmital@hotmail.com, kapilmital@rediffmail.com

Website : www.seek&source.com/kayson

CETTIFICATE OF TEST

ELECTRICIAN'S RUBBER GLOVES

TESTED TO 22000 VOLTS LENGTH : 380mm. SIZE : 10

Mfg. Date : JUNE 2002.

LOT SERIAL NO.1701 TO 2075 (QTY 375 PAIRS)

		NATURE OF TEST	ISS TEQUIREMENT	RESULTS
A		<u>ELECTRICAL TEST</u>		
	i	Leakage Current At Proof Voltage 22000 Volts	Maximum 16 Mili Ams	10 TO 12 Mili Ams
	ii	Leakage Current At Working Voltage 4000 Volts	Less than 2500 Micro Ams	< 2200 Micro Ams
	iii	High Voltage Break Down Test	Minimum 25000 Volts	> 28000 Volts
B		<u>Physical Properties Test</u>		
	i	Tensil Strength Test	10Mpa Minimum	> 16Mpa
	ii	Elongation Test	500 % Minimum	> 600 %
C		<u>Puncture Resistance Test</u>	Minimum 18KN/m	> 28KN/m
D		<u>Moisture Absorption Test</u>	Maximum 5 mg/ cm ²	< 3.80mg/cm ²


Certified for and on behalf of

For M/S. KAYSON INTERNATIONAL,


Authorized Signatory:



A copy of this document/
has been recorded with the Chamber


Authorized Signatory
Bombay Chamber of Commerce & Industry
Regn. No. 2253 Date 17 JUL 2002

NARESH WAMAN PARULEKAR

KAYSON INTERNATIONAL

B-232, OSHIWARA INDUSTRIAL CENTRE, OPP. GOREGAON BUS DEPOT,
NEW LINK ROAD, GOREGAON (WEST), MUMBAI - 400 104.

PHONE : 878 7663, FAX :91-22-878 7664

E-mail : kapilmital@hotmail.com, kapilmital@rediffmail.com

Website : www.seek&source.com/kayson

Date : 29/06/2002.

CETTIFICATE OF TEST

ELECTRICIAN'S RUBBER GLOVES CONFIRMING TO IS : 4770/1991

TYPE - I TESTED TO 5000 VOLTS LENGTH : 380mm. SIZE : 10

Mfg. Date : JUNE 2002.

LOT SERIAL NO.1101 TO 1650 (QTY 550 PAIRS)

		NATURE OF TEST	ISS TEQUIREMENT	RESULTS
A		<u>ELECTRICAL TEST</u>		
	i	Leakage Current At Proof Voltage 5000 Volts	Maximum 4 Mili Ams	< 3.5 Mili Ams
	ii	Leakage Current At Working Voltage 650 Volts	Less than 400 Micro Ams	< 350 Micro Ams
	iii	High Voltage Break Down Test	Minimum 6000 Volts	> 10000 Volts
B		<u>Physical Properties Test</u>		
	i	Tensil Strength Test	17Mpa Minimum	> 20Mpa
	ii	Elongation Test	600 % Minimum	>700 %
C		<u>Puncture Resistance Test</u>	Minimum 18KN/m	> 32KN/m
D		<u>Moisture Absorption Test</u>	Maximum 5 mg/ cm	< 4mg/cm

Certified for and on behalf of

For M/s KAYSON INTERNATIONAL,

[Signature]
Authorized Signatory



A copy of this document has been recorded with the Chamber

[Signature]
Authorized Signatory
Bombay Chamber of Commerce & Industry
Regn. No. 57234 Date

11 JUL 2002
NARESH WAMAN PARULEKAR

19/C-927
[Signature]